



SHREE FIRE SERVICES



Authorized Sales-Distributors

In All Kind of Fire Extinguishers, Appliances & Safety Equipments Specialized in Fire Hydrant System, Fire System, Sprinkler System & Fire Alarm System, CCTV System

Vijay Chowk, (Shivshrushti Killa Road) Dhananjay Kirana Store, Akliji,
Tal. Malshiras, Dist. Solapur 413101 ☎ 9503594004, 9097594004

Ref.No. SFS

• Certificate •

No. **1237**

This is Certify that

Dhanashailya Vidyakanya, Girzani, Akliji
Baniv Road, Tal-Malshiras Dist-Solapur

Date 09/06/2026 are Refilled, Required following type of Fire Extinguishers According to IS 2190. The Hydraulic Pressure Test is out of 30 kg/cm² and 24 Hour's Leakage Detection Test is Passed & Following Fire Extinguishers are Ready to use in Emergency.

Fire Extinguishers Refilled Date : 09-06-2026
Fire Extinguishers Next Due Date : 08-06-2027
24 Hours Leakage Detection Test : PASS / FALL

Sr. No.	Type of fire Extinguishers	Capacity	Qty.	Remark	Signature
1	ABD typed fire refilling	4kg	12NO	OK	

NOTE : ALL FIRE EXTINGUISHERS NEED YEARLY REFILLING FOR SAFE OPERATING

Hoping Your Valuable response assuring you the best of service at all times.
Thanking You.

Shree Fire Services

Proprietor

For, SHREE FIRE SERVICES