

State of Maharashtra
Water Supply and Sanitation Department
Senior Geologist
Ground Water Survey & Development Agency, Solapur
Ground Floor New Central Administrative Building
Collector Office Campus, Solapur 413003



Phone No. (0217) 2725875
E-Mail spr_gsa@yahoo.co.in

To,
Mr. DHANSHALYA VIDYALAYA, GIRZANI,
GIRZANI, TAL. MALSHIRAS,
Dist. SOLAPUR.

SDL/AKuj/Che/69/2026
Date 23/06/2026

Chemical Water Analysis Report Sub Divisional Laboratory Akuj

Sr. No.	Tahuka	Village	Source BW/DW	Station code	Location	Lab Ref	Date of collection	Date of Analysis	Colour	Odour	pH	E.C. $\mu\text{mho/cm}$	TDS mg/L	Tur NTU	TH mg/L	Fe mg/L	TA mg/L	Cl mg/L	SO ₄ mg/L	F mg/L	NO ₃ mg/L
1	MALSHIRAS	GIRZANI	FILTER	-	DHANSHALYA VIDYALAYA, GIRZANI	ACP27	19-06-2026	19-06-2025	Colourless	Odourless	7.5	313	200	0	50	0	50	0	0	0	0.0
									BIS (10500----200+-05) Highest Desirable Limit		6.5-8.5	-	500	--	300	0.3	200	250	200	1	45
									BIS (10500----2004-05) Permissible Limit		>8.5		2000	>10	600	No Relaxation	600	1000	400	1.5	No Relaxation


Cond -Electrical Conductivity, T.D.S. -Total Dissolved Solids, Turb -Turbidity,

Fe - Iron, T_Alk - Total Alkalinity, Cl - Chloride, F- Fluoride, SO₄ - Sulphate, NO₃ - Nitrate.

This report is restricted only for the Sample/s is submitted to this Laboratory.
This Sample/s is/are not collected by this Laboratory

Senior Geologist
Ground Water Survey & Development Agency
Solapur

State of Maharashtra
Water Supply and Sanitation Department



Senior Geologist
Ground Water Survey & Development Agency, Solapur
Ground Floor New Central Administrative Building
Collector Office Campus, Solapur 413003

Phone No. (0217) 2725875
E Mail spr_gsd@yahoo.co.in

To,
Mr. DHANSHAILYA VIDYALAYA, GIRI
GIRZANI, Tal. MALSHIRAS,
Dist. SOLAPUR

SDL/Akluj/Bact/69/2026
Date- 23/6/2026


Bacteriological Water Analysis Report

Sub Divisional Laboratory Akluj

Sr. NO.	Taluka	Village	Source BW/D W	Station code	Location	Lab Ref	Date of collection	Date of Analysis	Total coliforms	Thermotolerant coliforms	E.Coli	Remark
1	Malshiras	GIRZANI	FILTER	-	DHANSHAILYA VIDYALAYA, GIRZANI	ABP46	19-06-2026	19-06-2026	0	-	-	Water is Fit

Remark :

If the water sample is nonpotable (unfit) ,sample must be rechecked after chlorination.After that It is potable then only one use it for Drinking
This report is restricted only for the Sample/s is Submitted to this Laboratory.
This Sample/s is/are not Collected by this Laboratory


Senior Geologist
Ground Water Survey & Development Agency
Solapur